

Introduction

1. XBDM-MINI is rated for 15A and must be fed from 15A rated devices with an output circuit breaker. XBDM-MINI offers no overcurrent protection and must be installed per local code requirements.
2. Insure both utility and UPS source are in phase with each other.

Connection Procedure

1. Toggle bypass switch to desired source.
2. Connect per below drawings. Sources can be energized.
3. Connect load.

UPS Isolation Procedure

1. Move bypass switch to "utility" to isolate UPS.
2. Disconnect plug to UPS.
3. Reverse process when reconnecting UPS source.

Utility Isolation Procedure

1. Move bypass switch to "UPS" to isolate utility.
2. Disconnect plug to utility.
3. Reverse process when reconnecting utility source.

